

UNION

CERTIFICATION

EUROPE



## CERTIFICATE OF CONFORMITY

EUROPE CERTIFICATION UNION CO.,LTD

according to the requirements established in the standards listed below

Certificate No: ECU-BJE-11435-QAUS

Holder: 

Manufacturer: 

Product: THERMAL INSULATION PANNEL WITH METAL DECORATING

Model(S): AC1-001,AE2-001,AG3-001 ,AD4-001,AG5-001,B286-001,B17S-001,B177-001,  
AU9-001,3510-001,AV12-001,AE13-001

Test Number: ESC-BJE-201411-EMC

Directives: 305/2011/EU CPR

Standards: BS 4841-5:2006



**Conclusion:**

This assessment is based on an evaluation of the technical file of the above mentioned product and it is to certify that the technical file has been made in compliance with the items established in the above mentioned Directives. Certificate query: [www.euroceun.co.uk](http://www.euroceun.co.uk)

Certificate Issue Date :

Apr.07,2014



序号 No.	检验项目 Test items	检验方法 Test methods	标准要求 Standard requirements		检验结果 Test results	结论 Conclusion
1	Fire growth rate index(FIGRA), W/s	GB/T 20284-2006	B	$\leq 120$	48	合格 Qualified
2	Total heat release in 600s (THR <sub>600s</sub> ),MJ	GB/T 20284-2006		$\leq 7.5$	1.6	
3	Horizontal length of flame spread (LFS),m	GB/T 20284-2006		<试样边缘 <smample edge	符合要求 Up to the requirement	
4	Flame height (F <sub>s</sub> ),mm	GB/T 8626-2007		$\leq 150$	50	
5	Smoke generation rate index (SMOGRA), m <sup>2</sup> /s <sup>2</sup>	GB/T 20284-2006	S2	$\leq 180$	28	合格 Qualified
6	Total smoke production in 600s (TSP <sub>600s</sub> ),m <sup>2</sup>	GB/T 20284-2006		$\leq 200$	104	
7	Flaming droplets/particles	GB/T 20284-2006	d0	No flaming droplets/particles in 600s	符合要求 Up to the requirement	合格 Qualified
8	Filter paper burned or not	GB/T 8626-2007		Filter paper not burned	符合要求 Up to the requirement	
9	Smoke toxicity	GB/T 20285-2006	t1	Up to ZA <sub>3</sub>	ZA <sub>3</sub>	合格